



Materials/Finishes:	Electro-Galvanized (11WSG)	T-304 Stainless (11WSSS)
	T-316 Stainless (11WSSX)	
Service:	Designed for the suspension of stationary insulated pipe lines. Insulation protection shield is spot welded in place.	
Ordering:	Specify figure number, finish and hanger size.	
Notes:	To determine proper hanger size, use hanger selection guide below. Upper locknut must be tightened securely to assure proper hanger performance.	

PIPE SIZE	THICKNESS OF PIPE INSULATION					
	1/2"	1"	1-1/2"	2"	2-1/2"	3"
1/2	1-1/2	2-1/2	3-1/2	5	6	7
3/4	2	3	3-1/2	5	6	7
1	2	3	4	5	6	7
1-1/4	2-1/2	3-1/2	4	5	6	7
1-1/2	2-1/2	3-1/2	5	6	7	8
2	3	4	5	6	7	8
2-1/2	3-1/2	5	6	7	8	10
3	4	5	6	7	8	10
3-1/2	5	6	7	8	10	10
4	5	6	7	8	10	10
5	6	7	8	10	10	12
6	7	8	10	10	12	12
8	10	10	12	12	14	16
10	12	12	14	16	16	18
12	14	14	16	18	18	20
14	16	16	18	18	20	20
16	18	18	20	20	24	24

PROJECT INFORMATION	APPROVAL STAMP
Project:	APPROVED AS NOTED
Address:	NOTES:
Contractor:	
Engineer:	
Date:	
APPROVED	
NOT APPROVED	