



<b>Materials/Finishes:</b>	Copper Epoxy Coated ( <i>COPPER-GARD</i> ) Malleable Iron (41CT) Solid Brass (41CTS <sub>B</sub> )
<b>Service:</b>	Designed for the suspension of non-insulated stationary copper tubing, horizontally or vertically.
<b>Approvals:</b>	Complies with Federal Specification WWH-171-E (Type# 25), A-A-1192A (Type# 12), Manufacturers' Standardization Society SP-58 (Type# 12).
<b>Ordering:</b>	Specify figure number, finish and pipe size.
<b>Notes:</b>	Copper epoxy coated ( <i>COPPER-GARD</i> ). <i>COPPER-GARD</i> products offer superior corrosion protection due to the epoxy coating over electro-galvanized material. The alternative copper plating that has been done historically identifies the product and is not intended for protection. Refer to MSS SP58, 13.3.

TUBE SIZE	TUBE OD	SCREW	A	B	C	D	WGT EACH (LBS)	MAX REC LOAD (LBS)
1/2	0.625	10-24	3/8-16	11/16	1-7/8	1-1/8	0.087	180
3/4	0.875	10-24	3/8-16	13/16	2-1/4	1-3/8	0.096	180
1	1.125	10-24	3/8-16	15/16	2-1/2	1-5/8	0.128	180
1-1/4	1.375	10-24	3/8-16	1-1/16	2-7/8	1-7/8	0.141	180
1-1/2	1.625	10-24	3/8-16	1-3/16	3	2-3/16	0.179	180
2	2.125	10-24	3/8-16	1-7/16	3-1/2	2-11/16	0.229	180

PROJECT INFORMATION	APPROVAL STAMP
Project:	APPROVED AS NOTED
Address:	NOTES:
Contractor:	
Engineer:	
Date:	
APPROVED	
NOT APPROVED	